

ORDINANCE #19-7
AN ORDINANCE ADOPTING A FIRE PREVENTION CODE
PRESCRIBING REGULATIONS GOVERNING CONDITIONS
HAZARDOUS TO LIFE AND PROPERTY FROM FIRE OR
EXPLOSIONS AND ESTABLISHING A BUREAU OF FIRE
PREVENTION AND PROVIDING OFFICERS THEREFORE
AND DEFINING THEIR POWERS AND DUTIES

Be it ordained by the NORWOOD PARK FIRE PROTECTION DISTRICT;

Section 1: Adoption of International Fire Code-Life Safety Code

WHEREAS, the Norwood Park Fire Protection District, an Illinois municipal corporation, of Cook County, Illinois was created pursuant to the provisions of the Fire Protection District Act; and

WHEREAS, 70ILCS 705/6 provides that the Board of Trustees has full authority to pass all necessary Ordinances; Rules and Regulations for the proper management and conduct the business of the Board of Trustees of the Fire Protection District for carrying into effect the objects for which the District was formed; and

WHEREAS, 70 ILCS 705/11 provides that the Board of Trustees has the power, legal duty and obligation to provide as nearly adequate protection from fire for all persons and property within the District as possible, and to prescribe necessary regulations for the prevention and control of fire therein, and grants to the Board of Trustees the express power to adopt and enforce Fire Prevention Codes and Standards parallel to National Standards.

NOW, THEREFORE, BE IT ORDANED by the Board of Trustees of the Norwood Park Fire Protection District, Cook County, Illinois, as follows:

I. FIRE CODE-LIFE SAFETY CODE

ADOPTED MODIFICATIONS

There is hereby adopted by reference, as if fully set out at full length herein, for the purpose of prescribing regulations governing conditions hazardous to life and property from fire or explosion, there certain Codes. Which are:

- A. NFPA 101 Life Safety Code – 2015 Edition promulgated by the National Fire Protection Association, Batterymarch Park, Quincy MA 02269. The purpose of this code is to prescribe requirements and controls to safeguard life from fire and similar emergencies.
- B. ICC International Fire Code – 2018 recommended by the International Code Council, Inc., except as specifically amended, deleted, or modified herein.

The purpose of this Code is to prescribe requirements and controls to safeguard life from fire and similar emergencies.

II. AMENDMENTS TO THE ICC INTERNATIONAL FIRE CODE / 2018

The following sections of the 2018 International Fire Code are hereby amended or added:

Section 101.1 Insert the Norwood Park Fire Protection District

Section 105 Permits: Delete the section in its entirety.

Section 106.1 Add the following: The plan review for all applications over 5,000 square feet shall be sent to a third party for review at the fire officials discretion. The cost incurred to be the responsibility of the contractor.

Section 109.1 Delete the second sentence and add the following: The Fire District Board shall be the Board of Appeals.

Section 109.3 Fees See The Norwood Park Fire Protection District fee schedule.

Section 110.4 Penalties: See the Norwood Park Fire Protection District fee schedule.

Section 110.5 Vacant or Fire Damaged Structures: Add the following: Every person owning or having charge or control of any vacant or fire damaged building shall remove all combustible waste and refuse there from and lock and barricade or otherwise secure all windows, doors and other openings in the building to prohibit entry by unauthorized persons.

Section 503.7 Add the following: Where cul-de-sacs are permitted, they shall be not less than eighty feet (80') in diameter. A clear pavement width measured at the outer perimeter of the cul-de-sac of twenty-four feet (24') shall be maintained at all times

Section 505.1 Premises identification add the following: The use of script address is not allowed.

Section 505.1.1 Add the following Tenant Identification: All buildings with multiple tenants or units shall have signs in the corridor across from the elevator door. This direction signage shall indicate the direction to each number tenant space. All tenant spaces shall have a sign, which indicates the tenant space number. The signs shall be constructed of durable materials, be

permanently installed and be readily visible. Letters and numbers shall contrast with the background and shall be a minimum of 2 inches in height.

Section 505.1.2 Add the following: When a house, multi family, commercial or industrial building has an additional entrance other than the front street an additional address shall be provided. Provide an address for all garages, which do not front on the street (side yard, rear yard or alley).

Section 903.2.1 Group A change all group A to 1,000 square feet

Section 903.2.3 Group E change 12,000 to 1,000 square feet

Section 903.2.4 Group F-1 change 12,000 square feet to 1,000 square feet.

Section 903.2.7 Group M change 12,000 to 1,000 square feet

Section 903.2.9 Group S-1 change 12,000 to 1,000 square feet

Section 903.2.9.1 Motor vehicle repair garages over 1,000 square feet.

Add the following new sections 903.2.13 – 903.2.17 regarding fire sprinkler systems.

Section 903.2.13 All new construction over one (1) story in height and all other one (1) story buildings over one thousand (1,000) square feet in area.

Section 903.2.14 All basements in new construction.

Section 903.2.15 All business occupancies over one thousand (1,000) square feet.

Section 903.2.16 All existing Group S-1 over seven thousand (7,000) square feet.

Section 903.2.17 All existing hotels, motels boarding houses, rooming houses and dormitories.

Section 903.6 Add the following: Additional design requirements: all system shall comply with the additional design requirements.

Section 903.6.1 The maximum friction loss due to pipe friction in the system shall be forty (40) psi at the design flow.

Section 903.6.2 The system shall be designed with a minimum 10-pound safety cushion at the design flow.

Section 903.6.3 Floor plan and zone chart. A floor plan showing the sprinkler and alarm zones shall be provided in the sprinkler riser room.

Section 903.6.4 Whenever a backflow protection device is required to be installed on an existing sprinkler system, the system shall be reviewed to assure the design density or upper pressure for a pipe schedule system comply with the code. If the design pressure is inadequate, the automatic sprinkler system shall be redesigned as needed to be in compliance with the required design density or upper pressure for pipe schedule systems.

Section 905.3.1 Add the following new line: When any floor of the building is three (3) or more stories in height.

Section 905.3.9 Add the following new section: Public and private access is provided to each building (including buildings under construction) so the first responding pumper unit will be able to be located so that all points of the interior of the building may be reached by one hundred fifty feet (150') of initial attack hose from where the fire apparatus sets up operations.

Section 905.3.9.1 Add the following new section: Where the size and height of the building does not allow section 905.3.9 to be met, an interior standpipe system in compliance with the applicable sections of 905.4, 905.5 or 905.6 may be permitted as an exception.

Section 907.1.4 Add the following: Zone chart. A floor plan with a zone chart shall be provided at the enunciator and the fire sprinkler room.

Sections 907.2.8.1 and 907.2.8.2 Delete the sections and add the following: All group R-1 shall have a complete automatic fire alarm system.

Section 907.2.9 Delete the section and add the following: All group R-2 shall have a complete automatic fire alarm system.

Exception: Existing buildings of group R-2 with six (6) units or less, such as lodging houses, dormitories, apartments and similar occupancies.

Section 907.2.19 Covered malls: Delete exceeding 50,000 square feet in total area

Section 907.2.24 Add the following section: All buildings with multiple uses including residential shall have a complete automatic fire alarm system.

Section 907.2.25 Add the following section: All other buildings over one (1) story in height; and one (1) story buildings over one thousand (1,000) square feet.

Section 907.2.26 Add the following: Existing building one (1) story buildings under five thousand (5,000) square feet.

Section 907.9 Add the following: Panel identification: An outside strobe light shall be located at the entrance providing access to each alarm and/or annunciator panel.

Section 907.10 Add the following: Annunciator Panel: An annunciator panel is required where the fire alarm control panel is not visible from the building exterior. The annunciator panel shall be visible from the exterior of the building.

Section 907.11 Add the following: Outside Alerting Device: All fire alarm and fire suppression systems shall have an outside alerting device of a type and at a location approved by the code official.

Section 907.12 Add the following: Duct detectors: All duct smoke detectors installed or repaired after the effective date of this ordinance shall signal a supervisory condition only.

Section 907.13 Add the following: Systems Out of Service: Fire alarm systems shall be maintained in service at all times. Systems shall not be out of service for more than eight (8) hours for maintenance or repair.

Section 907.14 Add the following section: All smoke detector wiring must be in its own raceway.

Section 909.22 Add the following: Where required: In addition to systems being required in other sections of the code all new construction shall have a smoke control system in the following locations.

Section 909.22.1 Sprinklered building: In all sprinklered buildings with a gross area (combined area of all floors) exceeding forty thousand (40,000) square feet, including all unlimited area buildings as defined in section 507

Section 909.22.2 Multiple story buildings or building exceeding a specified height: All buildings over three (3) stories or thirty-five feet (35') in height, whichever is less.

Section 9198 Add the following: False Fire Alarm Service Charge:

Section 918.1 Charge: A charge of up to five hundred dollars (\$500) per call shall be made to the user of automatic fire alarm facilities, installed and maintained by others, which initiates a response by the Norwood Park Fire Protection District for a false alarm being given or transmitted by these facilities to the District.

Section 919.2 Time period: This charge shall be for each false alarm transmitted and responded to by the Norwood Park Fire Protection District during any ninety (90) day period commencing with the third (3rd) false alarm transmitted during any ninety (90) day period, whether caused by malfunctioning or intentionally or negligently misused or abused facilities or equipment, and which results in a the fire suppression and/or rescue apparatus and equipment being unnecessarily called to the property in response thereto. The fourth offense within 90 days will be one hundred dollars (\$100), fifth offense will be three hundred dollars (\$300) and any offense thereafter will be five hundred dollars (\$500). All charges shall be paid within thirty (30) days of the mailing or delivery of an invoice. Failure to pay may result in Village Licenses being revoked or suspended.

Section 1008.3 Add the following: All emergency light wiring shall be in its own raceway.

Section 1013.6.1 Add the following: All exit signs shall have red letters.

Section 1013.6.3.1 Add the following: All exit light wiring must be in its own raceway.

Section 5704.2.9.6.1 Add the following: The storage of cryogenics outside is not allowed.

Section 5706.2.4.4 Add the following: The storage of flammable liquids outside is not allowed.

Section 5806.2 Add the following: The storage of flammable liquids outside is not allowed.

Section 6104.2 Add the following: The storage of liquefied petroleum gases outside is not allowed. The storage of propane for sale shall comply with the provisions of this chapter.

Chapter 45 Change the following referenced standards
ICC

Delete the International Existing Building Code
Change the International Plumbing Code to the Illinois Plumbing Code
NFPA
Change or add the standards with the edition listed.

Adopt the following Appendices: E.

NFPA 2 - 2016	NFPA 11 - 2016	NFPA 12 – 2018	NFPA 12A-2018	NFPA 13 – 2019
NFPA -13D 2019	NFPA 13R – 2019	NFPA 14 – 2019	NFPA 15 – 2017	NFPA - 16 2019
NFPA 17 – 2017	NFPA 17A - 2017	NFPA 18 - 2017	NFPA 20 – 2016	NFPA 25 – 2014
NFPA 30 – 2018	NFPA 30A – 2018	NFPA 30B- 2019	NFPA 31 – 2016	NFPA 32 – 2016
NFPA 33 – 2018	NFPA 34 – 2018	NFPA 35 – 2016	NFPA 36 – 2017	NFPA 40 – 2019
NFPA 45- 2019	NFPA 50 – 2001	NFPA 51 – 2018	NFPA 51B – 2019	NFPA 61 – 2017
NFPA 70 – 2017	NFPA 72 – 2016	NFPA 85 – 2019	NFPA 120 – 2015	NFPA 252 – 2017
NFPA 259 – 2018	NFPA 265 – 2019	NFPA 268 - 2017	NFPA 409 – 2016	NFPA 655 – 2017
NFPA 664 – 2017	NFPA 701 – 2019	NFPA 704 – 2017	NFPA 1123- 2018	NFPA 1124 – 2017
NFPA 2001 – 2018	NFPA 2010 - 2015			

Section 2: Establishment and Duties of the Bureau of Fire prevention

- a. The Fire Prevention Code shall be enforced by the Bureau of Fire Prevention in the Fire Department of the Norwood Park Fire Protection District, which is hereby established and which shall be operated under the supervision of the Chief of the Fire Department.
- b. The Chief Inspector in charge of the Bureau of Fire Prevention shall be appointed by the Chief of the Fire Department. The appointment shall continue during good behavior and satisfactory service, and he/ she shall hold this office at the pleasure of the Chief of the Fire Department.
- c. The Chief of the Fire Department may detail members of the Fire department as inspectors as shall from time to time be necessary. The Chief of the Fire Department shall recommend to the Board of Trustees the employment of Technical Consultants, who, when such authorization is made, may be hired by the Chief of the Fire Department.
- d. A report of the bureau of Fire Prevention shall be made annually and transmitted to the Chief Executive Officer of the municipality; it shall contain all proceedings under this code, with such statistics as the Chief of the Fire Department may wish to include therein; The Chief of the Fire Department shall also recommend and amendments to the Code which, in his judgment shall be desirable.

Section 3: Definitions

- a. Wherever the word “municipality” is used in the Fire Code, it shall be held to mean the Norwood Park Fire Protection District.

b. Wherever the term "Corporation Counsel" is used in the Fire Code, it shall be held to mean the attorney for the Norwood Park Fire Protection District.

Section 4: Establishment of Limits of Districts in which storage of explosives and blasting agents is to be prohibited.

The limits, in which storage of explosives and blasting agents is prohibited, are hereby established as follows: within the limits of the Norwood Park Fire Protection district.

Section 5: Establishment of limits of Districts in which Storage of Flammable Liquids in outside aboveground Tanks to be prohibited.

a. The limits in which storage of flammable liquids in outside aboveground tanks is prohibited, are hereby established as follows; within the limits of the Norwood Park Fire Protection District boundaries.

b. The limits in which new bulk plants for flammable and combustible liquids are prohibited, are hereby established as follows: within the limits of the Norwood Park Fire Protection District boundaries.

Section 6: Establishment of limits in which Bulk Storage of Liquefied Petroleum is to be restricted.

The limits, in which the bulk storage liquefied petroleum is restricted, are hereby established as follows: within the limits of the Norwood Park Fire Protection District boundaries.

Section 7: Temporary waivers from Code provisions.

The Chief of the Fire Protection District shall have the power to waive the application of any provisions of the Fire Code, upon application in writing by the owner or lessee, or his duly authorized agent, when there are practical difficulties in the way of carrying out the strict letter of the Code, provided that the spirit of the Code shall be observed.

The particulars of such modifications when granted or allowed and the decision of the Chief of the Bureau of Fire Prevention thereon shall be entered upon the records of the Fire Protection District and a signed copy shall be furnished to the applicant.

Section 8: New materials, Processes or occupancies which may require permits.

The Board of Trustees, the Chief of the Fire Protection District and the Chief of the Bureau of Fire Prevention shall act as a committee to determine, specify, after giving affected persons an opportunity to be heard, any new materials, processes or occupancies, which require permits, in addition to those enumerated in said code. The Chief of the Bureau of Fire Prevention shall post such list in a conspicuous place in their office and distribute copies thereof to interested persons.

Section 9: Penalties.

Any person who shall violate any of the provisions of the Code hereby adopted or fail to comply therewith, or who shall fail to comply with any order hereunder, or who shall build in violation of any detailed statement of specifications or plans submitted an approved hereunder, or any certificate or permit issued hereunder, and from which no appeal has been taken, or who shall fail to comply with such an order as affirmed or modified by the Board of Trustees or by a court of competent jurisdiction, within the time fixed herein, shall severally for each and every violation and noncompliance respectively, be guilty of a misdemeanor, punishable by a fine of not less than \$100.00 nor more than \$500.00. The imposition of one penalty for any violation shall not excuse the violation or permit it to continue: and such person shall be required to correct or remedy such violation or defects within a reasonable time: and when not otherwise specified, each ten days that prohibited condition are maintained shall constitute a separate offense.

- Annual Life Safety Inspection No Charge
- 1st Re-inspection No Charge
- 2nd Re-inspection No Charge
- 3rd Re-inspection \$100.00
- 4th Re-inspection \$250.00
- 5th Re-inspection \$500.00

b. The applications of the above penalty shall not be held to prevent the enforced removal of prohibited condition

Section 10: Plan Review Fees

- Sprinkler System
 - Area 0-5000 Square Feet \$120.00
 - Area Over 5000 Square Feet (sent to a 3rd party for review and billing)
- Fire Pump
 - Addition to an Existing Sprinkler System \$60.00
 - *Only applies when replacing or adding to and existing system
- Fire Alarm System
 - Area 0-5000 Square Feet \$120.00
 - Area Over 5000 Square Feet (sent to a 3rd party for review and billing)
- Hood & Duct System \$60.00

Section 11: Inspection Fees

- Fire Pump Installation Inspection \$60.00
 - *Only applies when replacing or adding to an existing system

- Special Hazard System Acceptance Testing \$60.00
- Commercial Cooking Equipment Acceptance Testing
 - Light/Smoke Test \$60.00
 - Wet/Dry Chemical System Acceptance Test \$60.00
- Sprinkler System Acceptance Testing
 - Open Ceiling Inspection \$60.00
 - Hydrostatic Pressure Test \$120.00
- Fire Alarm System Acceptance Testing \$60.00
- Above/Below Ground Storage Tank Inspection \$60.00
- Final Inspection \$60.00
 - *To receive Certificate of Occupancy
- Special Use/Event Inspection \$240.00
 - *Includes permit review and pre-event inspections
- Fireworks Display Inspection \$480.00
 - *Includes permit review and pre-event inspection

Section 12: Fire Alarm Plan Submittal Checklist

This checklist is an effort to help provide a uniform approach for the design community and to provide owners and fire alarm designers with complete fire alarm design and submittal package requirements. It is the responsibility of the installer/designer to assure that all applicable code requirements are followed. All plans that are rejected and resubmitted will have additional fees charged for plan review.

The installation, renovation, addition, and/or maintenance of any fire alarm system shall comply with the following:

IMPORTANT:

No installation work shall be performed until the plans have been reviewed and approved. Expect up to 10 working days for plan reviews per submittal.

CHECKLIST: (All plans submitted must contain the following)

- Proof of Contractor’s license to be able to work within the Norwood Park Fire Protection District boundaries.
- Must be a certified electrician to install Fire Alarm System, must be licensed to install Fire Alarm Systems.
- Applicable codes are as follows:
 - NFPA 70 (2017 Edition)

-NFPA 72 (2016 Edition)

FIRE ALARM DRAWINGS:

- Must submit Fire Alarm drawings to the Norwood Park Fire Protection District 7447 W. Lawrence Ave. Harwood Heights, IL 60706
- Must submit 3 complete sets of fire alarm drawings, and one on CD in PDF format, and cut sheet/product information.
- The scaled drawings must include the following:
Title block to include the following information: Property name and address, Alarm Company name and address, date of drawing with space for revision dates, classification of the system per NFPA 72, who drew the drawing, the scale of the drawing, label the drawing as Fire Alarm System Standard or Addressable, Number of pages of the drawing.
- A legend of Fire Alarm System located on one sheet to indicate the type of device installed.
- A point-to-point wire diagram indicating the number of wires and gauge for each wire run. Include EMT size when appropriate.
- Include a statement in the installation notes under the symbols legend indicating the type of wire and gauge for each circuit.
- Include overall dimension of the building on each floor and square footage. Ceiling heights and ceiling construction must be identified on the drawings.
- Drawings need to be clear, legible and understandable. Drawings must be of a fire alarm design only.

CALCULATIONS

- Wire size, type, and resistance value
- Voltage drop calculations
- Battery calculations (minimum 48-hour battery back-up with 5 minutes of alarm)

SPECIFICATION SHEETS

All pertinent information shall be highlighted on the sheet. Please provide cut sheets for all devices installed:

- FACP - Type, Listing, Current Draw
- Batteries – Type, Listing, Current Draw
- Smoke Detector – Type, Configuration, Spacing, Current Draw
- Heat Detector – Type, Configuration, Spacing, Current Draw

- Duct Detectors – Supervisory signal only (reset stations need to be located near the panel)
- Manual Pull Stations – Type, Configuration
- Audible Appliances – Type, Rating, Power Tap
- Alarm Temporal Pattern
- Visual Appliances – Type, Configuration
- Protective Covers – Type, Attenuation
- Water Flow Devices – Type, Configuration
- Supervisory Device – Type, Configuration

ADDITIONAL SUBMITTAL INFORMATION REQUIRED

- A Record of Completion – shall be prepared and submitted at final inspection (Record of completion can be found in Section 7.2.1 in NFPA 72)
- A stamped set of plans and cut sheets approved by the Fire District shall be available at the work site at all times.

ROUGH INSPECTION

- A rough inspection of all fire alarm wiring shall be done by the Norwood Park Fire Protection District prior to the installation of drywall and/or ceiling materials.

FINAL INSPECTION

- No acceptance testing will be conducted prior to completion of construction. A minimum of 2 working days is needed to schedule test.
- Final acceptance is subject to Field Inspection.
- Re-inspection fees will be charged for re-inspections needed due to incomplete systems and/or failure to follow the above rules.
- An appointment is needed to be scheduled to have the final inspection completed. No testing will occur until all communicators are operational and being monitored.
- The contractor must provide the Norwood Park Fire Protection District with a certificate stating that the fire protection systems are installed in full compliance with NFPA standards, IBC/IFC requirements, and that all acceptance tests have been conducted. This certificate must be presented to the Fire Inspector at the time of the final acceptance test for the system.
- The contractor must also supply a NFPA 72 worksheet at the time of the fire alarm acceptance test.

SPRINKLER SYSTEM PLAN SUBMITTAL CHECKLIST

This checklist is an effort to help provide a uniform approach for the design community and to provide owners and sprinkler system designers with complete sprinkler system design and submittal package requirements. It is the responsibility of the installer/designer to assure that all applicable code requirements are followed. All plans that are rejected and resubmitted will have additional fees charged for plan review.

The installation, renovation, addition, and/or maintenance of any sprinkler system shall comply with the following:

IMPORTANT:

No installation work shall be performed until the plans have been reviewed and approved. Expect up to 10 working days for plan reviews per submittal

CHECKLIST: (All plans submitted must contain the following):

- Proof of Contractor's license to be able to work within the Norwood Park Fire Protection District boundaries.
- Must be licensed to install Sprinkler Systems with the Illinois Office of the State Fire Marshal.
- Applicable standards are as follows:
 - NFPA 13 (2019 Edition)
 - NFPA 13R (2019 Edition)
 - NFPA 13D (2019 Edition)
 - NFPA 14 (2019 Edition)
 - NFPA 20 (2019 Edition)
 - NFPA 25 (2017 Edition)

SPRINKLER SYSTEM DRAWINGS:

- Must submit Sprinkler System drawings to the Norwood park Fire Protection District 7447 W Lawrence Ave. Harwood Heights, IL 60706.
- Must submit 3 complete sets of sprinkler systems drawings and one on CD in PDF format and cut sheet/product information.
- The scaled drawings must include the following:
 - Title block to include the following information: Property name and address, Sprinkler company name/Contractor name, address and phone number, date of drawing with space for revision dates, classification of the system per NFPA 13, who drew the drawing, and a detailed scope of work.
- The specific type and quantity of sprinklers shall be provided on every page.

- All ceiling information including soffits, heights, construction type, slope, etc. shall be shown and noted with cross section detailed on the plans
- Provide a scaled site plan clearly showing the building fire department connection location and fire hydrant locations.
- Drawings need to be clear, legible and understandable. Drawings must be of a sprinkler system design only.

CALCULATIONS

- Hydraulic calculations shall clearly show the friction loss for the backflow preventer and include a graph curve sheet
- Fire hydrant flow test information shall be dated and less than one (1) year old.

SPECIFICATION SHEETS

All pertinent information shall be highlighted on the sheet. Please provide cut sheets for all devices installed.

- All sprinklers, valves, etc shall be included on the cut sheets.

ROUGH INSPECTION

A rough inspection of all sprinkler piping shall be done by the Norwood Park Fire Protection District prior to the installation of drywall and/or ceiling materials.

TESTS

A flush of the underground water mains must be made prior to the connection to the sprinkler system. All tests must be witnessed by the Norwood Park Fire Protection District.

All underground and overhead systems and piping should be hydrostatically tested with water at not less than 200 psi for two hours. This test must be witnessed by the Norwood Park Fire Protection District.

When the system is complete a 2 inch main drain test must be completed and must be witnessed by the Norwood Park Fire Protection District.

When the system is completed a wet system inspectors test must be completed and the inspectors test report must be provided to the Norwood Park Fire Protection District.

FINAL INSPECTION

No acceptance testing will be conducted prior to completion of construction. A minimum of 2 working days is needed to schedule test.

Final acceptance is subject to Field Inspection.

Re-inspection fees will be charged for re-inspections needed due to incomplete systems and/or failure to follow the above rules.

An appointment is needed to be scheduled to have the final inspection completed.

The contractor must provide the Norwood Park Fire Protection District with a certificate stating that the fire protection systems are installed in full compliance with NFPA standards, IBC/IFC requirements, and that all acceptance tests have been conducted. This certificate must be presented to the Fire Inspector at the time of the final hydrostatic/acceptance test.

Section 13: Repeal of Conflicting Ordinances

All former Ordinances or parts thereof conflicting or inconsistent with the provisions of this Ordinance or of the Code hereby adopted are hereby repealed.

Section 14: Validity

The Board of Trustees hereby declare that should any section, paragraph, sentence, or word of this Ordinance or of the Code hereby adopted be declared invalid, it is the intent of the Board of Trustees that it would have passed all other portions of this Ordinance independent of the elimination here from of any such portion as may be declared invalid.

Section 15: This Ordinance shall take effect and be in force from and after its approval as required by law.


PASSED AND APPROVED by The Board of Trustees of the Norwood Park Fire Protection District, Cook County, Illinois This 12th day of December 2019.

AYES: Skyba, Kolaski, Cichon, Avino, Rybak, Santoro-Cotton

NAY: 0


ABSENT: 0

APPROVED:



Andrew Cichon
President

ATTEST:



Joanne Rybak
Secretary



STATE OF ILLINOIS)
) SS
COUNTY OF COOK)

SECRETARY'S CERTIFICATE

I, **JOANNE RYBAK**, the duly qualified and acting Secretary of the Board of Trustees of Norwood Park Fire Protection District, Cook County, Illinois, do hereby certify that attached hereto is a true and correct copy of an Ordinance entitled:

ORDINANCE #19-7

**AN ORDINANCE ADOPTING A FIRE PREVENTION CODE
PRESCRIBING REGULATIONS GOVERNING CONDITIONS
HAZARDOUS TO LIFE AND PROPERTY FROM FIRE OR
EXPLOSIONS AND ESTABLISHING A BUREAU OF FIRE
PREVENTION AND PROVIDING OFFICERS THEREFORE
AND DEFINING THEIR POWERS AND DUTIES**

which Ordinance was duly adopted by said Board of Trustees at a meeting held on the 12th day of December 2019.

I do further certify that a quorum of said Board of Trustees was present at said meeting, and the Board met all the requirements of the Illinois Open Meetings Act.

IN WITNESS WHEREOF, I have hereunto set my hand this 12th day of December 2019.



Secretary, Board of Trustees
Norwood Park Fire Protection District

